

Subject: Joint Powers Agreement with Mendota Heights for ISD 197 Aquatic Center Sanitary Sewer Billing

Meeting Date: August 8, 2022	
Submitted/Presented by/Department: Ross Beckwith/City Engineer	
Action Type	
<input checked="" type="checkbox"/> Consent Item	<input type="checkbox"/> Discussion/Direction
<input type="checkbox"/> Public Hearing	<input type="checkbox"/> Informational Only
<input type="checkbox"/> Action/Motion	<input type="checkbox"/> Report
<input type="checkbox"/> Resolution	<input type="checkbox"/> Other:
Action	
Approve a Joint Powers Agreement with Mendota Heights for ISD 197 Aquatic Center sanitary sewer billing.	
Background	
<p>As design was underway for the new aquatic center at Two Rivers High School, it was determined that the best connection for sanitary sewer was into West St. Paul's sanitary sewer system. All the sink, showers and toilets connect to the sewer running under Delaware Avenue. The pool itself is connected to this main, but has reduced piping in place so the draining of the pool can be controlled to where it does not overwhelm our sewer system.</p> <p>A Joint Powers Agreement (JPA) is required to properly compensate West St. Paul for use of the sanitary sewer main that takes discharge from Mendota Heights.</p> <p>The City Attorney has reviewed the new contract agreement and finds it acceptable.</p>	
Attachments	
JPA (signatures needed)	
Previous Relevant Actions	
Alternatives	
Financial	
Budgeted: <input type="checkbox"/> Yes	<input type="checkbox"/> No Financial Impact
Fund:	Payment to West St. Paul will be based on water usage as determined by St. Paul Regional Water Services multiplied by West St. Paul's current sewer rates.
Department:	
Account:	
Amount:	